



CIVIC ENGINEERS AND ARCHITECTS

Ajay Kumar Gupta
BE (CIVIL)

No. CE&A/2025/04

Date 16/05/2025

STRUCTURAL STABILITY CERTIFICATE

To Whom It May Concern

This is to certify that I have conducted an inspection of the **DAV Public School (Senior Wing)** building located at **C-Block, Kailash Hills, Near C-Block Market, East of Kailash, New Delhi – 110065**.

The building is a **G+1 storeyed structure**, comprising a **framed RCC system** with columns, beams, and slab. A portion of the roof is constructed using **T-iron, ISMB sections, and stone slabs**, supported additionally by **load-bearing walls**. Upon inspection, no structural distress or visible cracks were observed. The overall condition of the building is found to be structurally stable.

The structure is deemed suitable to support the proposed **front façade cladding using Aluminium Composite Panels (ACP)** and associated elements, as well as the **construction of a parapet wall up to 1.5 meters in height at the terrace level** to ensure student safety.

Based on my assessment, the structure is **safe, sound, and fit for use as a school building**.

Manager
D.A.V. Public School (Recognised)
Kailash Hills, East of Kailash
New Delhi-110065

Principal
D.A.V. Public School (Recognised)
Kailash Hills, East of Kailash
New Delhi-110065

Er. AJAY KUMAR GUPTA, BE (CIVIL)
MCD Regn. No. SE/0771
C-7/223, 1st Floor, Shop No. 3, Sector-7,
Rohini, Delhi-110085

- Sanction of Bldg plan from MCD
- Structural Consultants
- Registered Engineers On
Municipal Corporation of Delhi Panel

Shop No. C-7/223, 1st Floor, Sector-7, Rohini, Delhi-85

M : 9717787930

Email id : ajay121961@gmail.com